


Kenneth A. Monroe, PE, MBA, CHC, PMP


Director – Engineering SIG (Standards Interpretation Group) The Joint Commission


Learning Objectives At the conclusion of this presentation, participants will be able to: Discuss The Joint Commission mission & deemed status Understand the survey process Describe the SAFER Matrix Understand which standards are scored most frequently in 2017 Discuss the process of Standards creation Understand the new and revised EP's in the LS and EC chapters We are NOT presenting a detailed EP discussion





































© Copyright, The Joint Commission

Survey Types Full U (Full Unannounced\Triennial) Med Def (Medicare Deficiency) SSU/OQPS (Special Survey Unit & Office of Quality and Patient Safety) ICM 2 or 3 (Intracycle Monitoring) Extension Survey (New building/services) Medicare Survey (CLD on Initial)

The Joint Commission

L	ife Safety Code Survey	or Days - 2018				
	Hospitals – Each Physical A	ddress = Min. 2 LSCS days <mark>(n</mark> e	ew)			
	Gross Building Square Footage					
	0 - 1,000,000	2 LSCS Days				
	1,000,000 - 1,500,000	3 LSCS Days				
	>1,500,000	LSC FD Review				
	Non Hospital Life Safety	Code Surveyor Days - 2018				
	Gross Buildin	g Square Footage				
	AHC / ASC	1 LSCS Day	Commiss			
	Med Def	1 LSCS Day	he Joint -			
	SSU / OQPS	1 LSCS Day	© Copyright, The Joint Commission			
The Joint C	Commission		රි ම			




LSCS Pre Survey Review


- SOC (BBI E-app) PFI's not visible to LSCS
- Previous report and ESC's
- Public web site
- Surveyor Resources




© Copyright, The Joint Commission


Survey Agenda: LSCS Arrives with Team								
	Day 1		Day 2					
0800 - 0900	Facility Orientation	0800 - 0815	Day #1 Morning Briefing					
0900 – 0930	Opening Conference/Introductions Only	0815 – 1200	Building Tour Cont'd					
0930 – 1045ish	Document Review	1200 – 1230	Lunch					
		1230 – 1430	EC/EM Sessions (Separate)					
1045 -	Pressure Relationships							
1200	(OR's/SPD)	1430 -	Enter day #2 Findings into report					
1200 – 1230	Lunch	1530						
1230 -	Building Tour	1530 -	Interim LSCS Exit/Team Exit					
1230 -	(End of day Findings)	1600						

























	STANDAR		1	See Leg	end	Document / Regularement		mency	Q 1/	0.2	Q 3/	Q 4/	1
Π I	I STANDAR	1-FPs		e Legei			i Frei	mency		Q 1/	<u> </u>	Q 3/	Q 4/
	STANDARD - E	P8 0				Document / Requirement		Frequ	ency	Semi	Q 2	Semi	Annual
	EC.02.03.05					Fire Protection and Suppression Testing and Inspectio	n						
	EP 1					Supervisory Signals-Including: Control valves; pressure supervisory; pressure tank, pressure supervisory for a dry j (both high and low conditions), steam pressure; water level supervisory signal initiating device; water temperature supervisory; and room temperature supervisory.		Quarter	ty				
	EP	5			+	Electric motor-anventine pumps tested under no-now conditions	MORE	ну	· · ·			-	
						Diesel-engine-driven fire pumps tested under no-flow conditions	Week	thy					
	EP	,				Water storage tank high and low level alarms	Semia	annually					
	EP	3				Water storage tank low water temp alarms (cold weather only)	Month	hiy					
	EP	•				Sprinkler systems main drain tests on all risers	Annu	ally					
	EP 1	D				Fire department connections inspected (Fire hose connections N/A)	Quart	terty					
	EP 1	1				Fire pump(s) tested – under flow	Annu	ally					
	EP 1	2				Standpipe flow test every 5 years	5 yea	rs					
	EP 1	3				Kitchen suppression semi-annual testing	Semia	annually					
	EP 1	4				Gaseous extinguishing systems inspected (no discharge req.)	Annu	ally					
	EP 1					Portable fire extinguishers inspected monthly	Month	hly					
	EP 1					Portable fire extinguishers maintained annually	Annu						
	EP 1	7				Fire hoses hydro tested 5 years after install; every 3 years thereafter	5 yea 3 yea						
	EP 1	8				Smoke and fire dampers tested to verify full closure	1 yea	r after insi	all years the	reafter			
	EP 1	9				Smoke detection shutdown devices for HVAC tested	Annu	ally	-				
	EP 2	0				All horizontal and vertical roller and slider doors tested	Annu	ally					
	EP 2	5				inspection and testing of door assemblies by qualified person	Annu	ally					
	EP 2	7		ľ		Documentation of maintenance testing and inspection activities for EPs 1-20 and 25 includes: activity name; date; inventory of devices, equipment or other items; frequency; contact info for person performing activity; NFPA standard; activity results							






















	ILSM changes on the report	
	CoP Text: (i) The hospital must meet the applicable provisions and must proceed in accordance with the Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12–1, TIA 12–2, TIA 12–3, and TIA 12–4.) Outpatient surgical departments must meet the provisions applicable to Ambulatory Health Care Occupancies, regardless of the number of patients served.	
	Likelihood to harm a patient/visitor/staff Select • Interim Life Safety Measures: Was the LS deficiency corrected on site? Yes No Observation Text:	
	In Out of Select activity -	(Commission
The	Joint Commission	© Copyright, The Joint Commission

Interim Life Safety Measures: Was the LS deficiency corrected on site? Related Interim Life Safety Measures (ILSMs) (Select All That Apply)	⊖Yes ●No			
EP-2 Fire watch or evacuation	EP-9 Enforce practices to reduce building flammable and combustible fire load			
EP-3 Post signage if exit compromised	 EP-10 Provide additional training on use of firefighting equipment EP-11 Conduct additional fire drill per quarter 			
EP-4 Inspect exits daily				
EP-5 Equivalent fire alarm and detection systems	EP-12 Inspect and test temporary systems monthly			
EP-6 Additional firefighting equipment	EP-13 Conduct education promoting awareness of deficiencies			
EP-7 Temporary construction partitions	EP-14 Train staff on fire safety features			
EP-8 Increase surveillance	EP-15 Other			










Scope	
Label	Definition
WIDESPREAD	Deficiency is pervasive in the facility, or represents systemic failure, or has the potential to impact most/all patients, visitors, staff (5 or more)
PATTERN	Multiple occurrences of the deficiency, or a single occurrence that has the potential to impact more than a limited number of patients, visitors, staff (3 or 4)
LIMITED	Unique occurrence that is not representative of routine/regular practice, and has the potential to impact only one or a very limited number of patients, visitors, staff (1 or 2)
The Joint Commission) () ()

	Likelihood to	Harm	
	Label	Definition	
н	GH	Harm could happen at any time	
M	ODERATE	Harm could happen occasionally	L
	w	Harm could happen, but would be rare	© Copyright, The Joint Commission
The .	Joint Commission		© Copyright, Th∈





Average RFIs Scored per Full/Initia	al Surveys B	y Program fo	or Calendar	Year 2016			
and YTD 2017 (As of 7/27/2017)							
	20)16	2017 YTD				
		Average		Average			
Program	Surveys	RFIs/Survey	Surveys	RFIs/Surve			
Ambulatory Care	640	14.6	410	17.4			
Hospital	1,442	20.5	820	30.3			
Nursing Care Center	292	6.1	141	9.3			
Behavioral Health Care	922	8.0	657	10.1			
Home Care	1,962	8.7	1,098	9.8			
Laboratory	736	8.5	429	9.5			
Office Based Surgery	87	9.4	55	9.7			
Critical Access Hospital	90	15.1	65	22.3			
Disease-Specific Care Certification	1,816	1.4	966	2.1			
Health Care Staffing Services Certification	193	0.5	121	0.9			



Commiss
Joint
The
Copyright,
0


ы.


Standard	2017	2016	2015
LS.02.01.35	86%	51%	46%
EC.02.05.01	73%	57%	58%
IC.02.02.01	72%	60%	59%
LS.02.01.30	72%	50%	50%
EC.02.06.01	70%	68%	62%
LS.02.01.10	66%	48%	45%
EC.02.02.01	63%	47%	39%
EC.02.05.05	62%	18%	12%
LS.02.01.20	62%	49%	51%
EC.02.05.09	59%	29%	30%





The Joint Commission


© Copyright, The Joint Commission





















	Challenges and Solutions for Life Safety - LS	
	Most frequently cited LS Standards	
	LS.02.01.35 – Sprinklers, etc.	
	LS.02.01.30 – Protect from Fire and Smoke	
	LS.02.01.10 – Effects of Fire/Heat/Smoke	
	LS.02.01.20 – Means of Egress	
	LS.01.01.01 –Life Safety Code Compliance	
	LS.02.01.34 – Provides/Maintains Fire Alarm System	
	LS.02.01.50 – Building Services Protect from Fire and Smoke	reion
	LS.02.01.70 – Fire/Smoke Prevention Requirements	© Copyright. The Joint Commission
	LS.01.02.01 – Interim Life Safety Measures	e. Joint
	LS.03.01.30 – Fire & Smoke Protection in Ambulatory Healthcare	richt. Tr
The Join	t Commission	© Copv



















































41



















































Chapter	NEW	MOVED	REVISED	REVISED & MOVED	DELETED
EC	29	31	22	8	0
LS	49	86	15	39	4
TOTALS	78	117	37	47	4
TOTAL EF Touched	P's				283


LS.O2.O1.30 EP-12 (was EP-11) In new buildings, all corridor doors are constructed to resist the passage of smoke, Positive latching hardware is required. Roller latches are prohibited. NFPA 101-2012: 18.3.6.3.1; 18.3.6.3.5; 18.3.6.4; 18.3.6.5; 18.3.6.3.10; 18.3.6.3.11)





LS.02.01.30 EP-13 (was EP-12) r – March, 2018 page 2


Note 2: For hospitals that use Joint Commission accreditation for deemed status purposes: Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces (except pantries) that do not contain flammable or combustible materials are not required to have a device capable of keeping the door fully closed if a force of 5 pounds is applied at the latch edge. In these cases, <u>roller latches on these doors that keep a door closed when a force of 5 pounds is applied are permissible</u>.


© Copyright, The Joint Commission


































































Standard	2017 Rank	% Non- compliant	EP	Summary	
LS.02.01.35 The Hospital provides equipment for extinguishing fires		59%	4	Manage systems for extinguishing fires including the integrity (nothing supported by sprinkler piping, missing escutcheons)	
	<u>1</u>	41% 5 Sprinkler heads are not damaged. They are free of corrosion, foreign materials, paint, and have necessary escutcheon plates installed			
		34%	14	Other issues, including: blocked access to fire extinguishers (Wildcard)	

Most Cited Standards - # 2					
Standard	2017 Rank	% Non- compliant	EP	Summary	
		45%	8	Labels utility system controls to facilitate partial or complete emergency shutdowns	
EC.02.05.01 The Hospital manages risks associated with its utility systems	2	40%	15	In critical areas the organization manages risk associated with Utility Systems, including Pressure relationships, Filtration, Air Exchanges (ach), and Temperature and Humidity	
		25%	16	In non-critical areas the organization manages risk associated with Utility Systems, including Pressure relationships, Temperature and Humidity	

Standard	2017 Rank	% Non- compliant	EP	Summary
LS.02.01.30 The Hospital provides and maintains building features to protect individuals from the hazards of fire and smoke	4	38%	3	Building and fire protection features: Existing Hazardous Areas
		32%	18	Smoke Barrier integrity
		30%	11	Corridor doors
		20%	19	Smoke barrier doors

		,		- # 5 & # 6
Standard	2017 Rank	% Non- compliant	EP	Summary
EC.02.06.01 The hospital establishes and maintains a safe and functional environment	5	66%	1	Safe environment, including ligature risks, stained ceiling tiles, mismanaged pull cords
		13%	26	Furniture and equipment
LS.02.01.10 Building and fire protection features are	6	39%	7	Building and fire protection general requirements: Fire-rated door
designed and maintained to minimize the effects of fire, smoke and heat.		38%	10 (now 14)	Building and fire protection general requirements: Barrier Penetrations

Standard	2017 Rank	% Non- compliant	EP	Summary
EC.02.02.01 The Hospital manages risks related to hazardous materials and waste	7	42%	5	Minimize risks with hazardous chemicals
		26%	12	Hazardous materials and waste labeling
EC.02.05.05 The Hospital inspects, tests and maintains (ITM) utility systems	8	52%	6	ITM of non-high risk utility equipment
		12%	5	ITM of infection control utility equipment

Standard	2017 Rank	% Non- compliant	EP	Summary
LS.02.01.20 The Hospital maintains the integrity of the means of egress	9	32%	11	Means of egress clear and unobstructed
	5	18%	1	Locking arrangements
EC.02.05.09 The Hospital inspects,		37%	6	Medical gas cylinder management
tests and maintains medical gas and vacuum systems.	10	25%	5	Medical gas shut off valves labeled and accessible